

Property Loss;

On June 28th at around 5:00pm my tech inspector and I walked into the pole building and heard a crackling and popping coming from the office in the pole building. We went in and found the room full of smoke with the equipment crackling and popping and smoking. We unplugged all the equipment so we wouldn't have a fire. After that we called Loren from the county and told him what was going on. While I was talking to Loren , we (my tech and I) checked the outlets for the power and found that the outlet were 220. After talking to Loren we saw Steve from the county and told him and showed him. We turned off the circuit breakers that powered those outlet for the night. The county came out in the morning to figure out what was going on. They spent all day trying to figure it out to no prevail. We had run alternative power to run a different computer and the PA system so we could run our Friday night racing.

On Monday morning I saw that the power was back on. I called Loren and asked what they found to be the problem. The county electricians came back out and fixed the problem. He found out and told me that there was a neutral wire that had come apart.

With this problem we lost several items and need to be replaced:

2-Westhold 45 transponder charging boxes (one is 3 years old and the other is 1 year old) \$800 each totaling \$1600.00 plus shipping. We have received a loaner until the chargers are replaced. There will be a rental fee for this but will come with the bill for chargers.

1- Swann security system w/4 cameras (1 year old) \$500

1-Dell computer desk top (2 years old) \$600 plus shipping

A total of \$2700.00 plus shipping for items that need to be shipped and rental fees.

Sincerely,

Oshkosh Speedzone

Larry Stratton

Jeff Lemiesz

